





TEST REPORT IEC 60947-6-1

Low-voltage switchgear and controlgear Part 6-1: Multiple function equipment – Transfer switching equipment

Report Number.....: 03601-A-20CB0032-S

Date of issue: 2020-07-24

Total number of pages 55

Name of Testing Laboratory

Co., Ltd.(EETI)

Applicant's name Zhejiang Tengen Electric Co., Ltd.

Address Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang

Province, P.R.China

Test specification:

Standard: IEC 60947-6-1:2005, AMD1:2013 for use in conjunction with IEC

60947-1:2007, AMD1:2010

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No.: IEC60947_6_1C

Test Report Form(s) Originator: SGS Fimko Ltd

Master TRF: Dated 2019-07-02

Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Page 2 of 55

Report No.: 03601-A-20CB0032-S

Test item description Automa		atic Transfer Switching Equipment		
Trade Mark:	TENGE	EN		
Manufacturer:	Sulv In Province	ng Tengen Electric Co., Ltd. dustrial Area, Liushi Town, Y ce, P.R.China	ueqing City, Zhejiang	
Model/Type reference:			NPL-125,TGQKPL-125	
Ratings:		V(main circuit);500V(control and auxiliary circuits);		
	Uimp:8kV(main circuit);4kV(control and auxiliary circuits); Ith: 125A; Ue: AC230V(2P),AC400V(3P,4P);			
	le: 63A,80A,100A,125A;			
	Utilization Category:AC-33A;			
	Icm: 17kA; Icw: 10kA/30ms;Iq:120kA;			
	Class of equipment: PC;			
	Method of controlling:ATSE;			
	2P, 3P	, 4P.	11 111 111	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s).				
	-ppiioar	<u></u>	-(AL"	
		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)		
Testing location/ address:		THE SHE		
Tested by (name, function, signature):		Wang Wei(Team leader)	WAS .	
Approved by (name, function, signature):		Chen Yuan (Supervisor)	Mari de	
☐ Testing procedure: CTF Stage 1:				
Testing location/ address:				
Tested by (name, function, signature):				
Approved by (name, function, signature):				
Approved by (name, function, signature)				
☐ Testing procedure: CTF Stage 2:				
Testing location/ address:				
Tested by (name, function, signature):				
Witnessed by (name, function, signature). :				
Approved by (name, function, signature):				
Tasking mass disease				
Testing procedure: CTF Stage 3 or 4:				
Testing location/ address	:			
Tested by (name, function, signature):				
Witnessed by (name, function, signature). :				
Approved by (name, function, signat	ure):			
Supervised by (name, function, sign	ature):			